


# Evaluating Biogas to Energy Options Northwest Regional Water Reclamation Facility Fox Lake, IL



74<sup>th</sup> Annual  
Indiana Water Environment Association Conference  
Indianapolis, Indiana  
November, 2010

Greg Droessler, P.E.  
Clark Dietz Inc.

# Village of Fox Lake



# Village of Fox Lake


## Northwest Regional Water Reclamation Facility



# Step #1 – Evaluate gas volume produced


- How much is produced? (cfm and cfd)
- How much is used? (cfm and cfd)
  - How much extra gas do you have?

**Average Digester Performance**



# Step #1 – Evaluate Gas production

- How much gas is used?
- How much gas is wasted?



**Goal: Put the wasted gas to use!**

## Step #2 – Determine the gas quality (sampling)

- BTU / CF (methane concentration)
- Siloxane concentrations
- H<sub>2</sub>S levels
- VOC levels

# Major Component Table

## Major Component –

Sample ID:	Conc. Unit	K0113b01
	Description:	Bio Gas, Fox Lake, IL, WWTP, 1/11/10
Methane	%	59.7
Carbon dioxide	%	39.4
Nitrogen	%	0.75
Oxygen	%	0.183
GHV, dry (14.73 psi) *	Btu/scf	606
Relative density *		0.941

\* Calculation based on major components listed.

**Note:** All major component concentrations were reported as a moisture and C<sub>2</sub> plus free basis and were normalized to 100%. Oxygen and Argon cannot be separated; therefore, the oxygen result includes a small amount of Argon. Some results may be reported with additional significance for reference.

# Compound Speciation - Siloxanes

## Compound Speciation – Siloxanes

Organic Silicon (siloxanes)	K0113b01	
	Bio Gas, Fox Lake, IL, WWTP, 1/11/10	
	ppmv as Si	ppmv
Tetramethyl silane	<0.05	<0.05
Trimethyl silanol	<0.05	<0.05
Hexamethyldisiloxane (L2)	0.82	0.41
Hexamethylcyclotrisiloxane (D3)	0.28	0.094
Octamethyltrisiloxane (L3)	<0.05	<0.02
Octamethylcyclotetrasiloxane (D4)	0.59	0.147
Decamethyltetrasiloxane (L4)	<0.05	<0.01
Decamethylcyclopentasiloxane (D5)	11.41	2.28
Dodecamethylpentasiloxane (L5)	<0.05	<0.01
Dodecamethylcyclohexasiloxane (D6)	1.21	0.202
Others. as L2	0.24	0.12
<b>Total:</b>	<b>14.55</b>	
<b>Total (Si, mg /M<sup>3</sup>):</b>	<b>17.25</b>	

Note: Others may include traces (BDL) of 10 target compounds. Some results may be reported with additional significance for reference. Tedlar bag often contributes a background level of <0.2 ppmv siloxanes due probably to the use of silicone-based lubricant on the valve stem.

# Compound Speciation – Sulfur Components

## Compound Speciation – Sulfur Components

Sulfur Compounds, ppmv as S	K0113b01
	Bio Gas, Fox Lake, IL, WWTP, 1/11/10
Hydrogen sulfide	62.6
Carbonyl sulfide	0.31
Methyl mercaptan	<0.05
Ethyl mercaptan	0.04
Dimethyl sulfide	<0.05
Carbon disulfide *	<0.05
i-Propyl mercaptan	0.08
t-Butyl mercaptan	0.06
n-Propyl mercaptan	0.07
Ethylmethyl sulfide	<0.05
Thiophene	<0.05
Diethyl sulfide	<0.05
Dimethyl disulfide *	<0.05
Ethyl methyl disulfide *	<0.05
Diethyl disulfide *	<0.05
Others (as S)	0.19
Total S: (ppmv)	63.4
(mg/M3)	85.8

Note: Some results were reported with additional significance for reference. The normal detection limit of each sulfur compound is 0.05-0.1 ppmv.

\* 1.0 ppmv as sulfur = 0.50 ppmv sulfur compound

# Gas Conditioning

Will biogas conditioning be required?

**YES – If you want the equipment to last more than 1 year!**

- Siloxane removal
  - < 5 ppb for microturbine
  - < 50 ppb for ICE generators
- H<sub>2</sub>S removal
  - < 5 ppm for microturbine
  - < 500 ppm for ICE generators
- Moisture removal



# Step #3 – Options for biogas use

- Dual-feed boilers
  - Digester heating
  - Building heat
- Engine generators
- Microturbines
- Others (air conditioning, vehicle fueling, synthetic natural gas production, etc.)



# Microturbines vs. Engine Generators

	<b>Advantages</b>	<b>Disadvantages</b>
<b>Microturbines</b>	<ul style="list-style-type: none"><li>• Cost effective</li><li>• Low install costs</li><li>• Pre-packaged systems</li></ul>	<ul style="list-style-type: none"><li>• May require service assistance</li><li>• Requires a very clean gas</li><li>• Newer technology that is rapidly updating</li></ul>
<b>Engine Generators</b>	<ul style="list-style-type: none"><li>• Familiar technology – has been used for at least 50 years</li><li>• Requires low pressure gas feed (typically less than 1 psi)</li><li>• Tolerates dirtier gas - higher H<sub>2</sub>S and siloxane levels</li><li>• Lots of options for size</li><li>• Less parasitic costs</li></ul>	<ul style="list-style-type: none"><li>• Requires a larger footprint</li><li>• More expensive to install</li><li>• Slightly higher operating costs</li><li>• Slightly less fuel efficient</li></ul>

Recommendation – Engine generator

# Step #4 – Determine Costs

- Capital costs
  - Equipment
  - Installation
- Annual O&M costs
- Other parasitic costs
  - Power for gas compression, conditioning, etc.
- Value of the power and heat produced

**All of these make up the Life Cycle Cost.**

---


# Life Cycle Cost Analysis

	Tech-3 Solutions	Martin Machinery	Kraft Power
Planning Period, years	20		20
Discount Rate, %	5.0		5.0
Electricity Cost per KW-Hr	\$0.070		\$0.070
Heat Recovery Value (per Therm)	\$0.65		\$0.65
Labor Cost per Hour	\$50.00		\$50.00
Capital Equipment Cost <sup>1</sup>	\$247,555		\$173,495
Installation Cost <sup>2</sup>	\$100,000		\$100,000
Rated Electrical Production (KW)	150		100
No. of Units on Duty	1		1
Annual Hours of Operation, each	6,570		6,570
Annual KW	985,500		657,000
Annual Electric Production Value	\$68,985		\$45,990
Heat Recovery (BTU/Hr)	777,943		499,582
No. of Units on Duty	1		1
Annual Hours of Operation, each	6,570		6,570
Annual Heat Recovery (BTU)	5,111,085,510		3,282,253,740
Annual Heat Recovery (Therms)	51,111		32,823
Annual Heat Recovery Value	\$33,222		\$21,335
Annual Maintenance Materials Cost	\$6,500		\$17,600
Annual Maintenance Hours	35		0 <sup>(3)</sup>
Annual Maintenance Labor Costs	\$1,750		0 <sup>(3)</sup>
Total Capital Cost	\$347,555		\$273,495
Annual Electric Value	\$68,985		\$45,990
Annual Heat Recovery Value	\$33,222		\$21,335
Annual Maintenance Costs	\$8,250		\$17,600
<b>Total Present Value</b>	<b>\$450,368</b>	<b>No Proposal Received</b>	<b>\$492,830</b>

Notes:

1. Capital equipment costs from Proposals received 7/21/10
2. Installation costs based on an exterior installation on a concrete foundation.
3. Kraft Power included all maintenance costs in a proposal to service the equipment at \$2.68 / run hour.

# Step #5 – Payback Analysis



**10 year payback on the investment!**

Questions.....?